



Intellidyne Reduction Study

[2010 - 2012]


SPECS:

System: 3-Ton 13 SEER Heat Pump

Location: Ocala, FL (Residence)

Installed: IntelliCon® AC – September 2011

Set Points: Cooling: 76 ; Heating: 70



RESULTS:

KWH Savings: 3985

Savings @ 0.12 per KWH: \$461.50

Energy Savings: 22%